

线路名称	电压等级 (kV)	额定电流 (A)	额定电流类型	最大历史电流 (A)	最大历史电流日期	负载率 (%)	线路性质	可开放容量 (kVA)	在途容量 (kVA)	所属主变		所属母线	挂接台区总数	挂接台区总容量 (kVA)	核算可开放容量 (kVA)
										变电站名称/主变名称	可开放容量 (MVA)				
安达113线	10	531	D5000维护值	434.91	2021-06-18	81.9	重载	0	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏I段母线	2	14000	0
安革215线	10	550	D5000维护值	49.04	2021-06-01	8.92	轻载	5818.83	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	0		5818.83
奥储2号112线	10	550	手工维护值	81.15	2021-04-07	14.75	轻载	5262.68	0	扬州.胥南变/1号主变		扬州.胥南变/10kV.10千伏I段母线	1	1880	5262.68
八一126线	10	455	D5000维护值	0.71	2021-05-20	0.16	轻载	5504.12	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏II段母线	0		5504.12
巴庄1号161线	10	459	手工维护值	251.66	2021-06-22	54.83	中载	1206.16	0	扬州.胥南变/1号主变	12.91	扬州.胥南变/10kV.10千伏VI段母线	21	17570	1206.16
巴庄2号162线	10	459	手工维护值	302.64	2021-04-18	65.93	中载	323.19	0	扬州.胥南变/1号主变	12.91	扬州.胥南变/10kV.10千伏VI段母线	10	8722	323.19
百寿121线	10	531	手工维护值	137.46	2021-04-24	25.89	轻载	4057.04	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏II段母线	34	7900	4057.04
北林211线	10	530	D5000维护值	0.06	2021-06-26	0.01	轻载	6424.68	0	扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	0		6424.68
北站116线	10	530	D5000维护值	19.28	2021-05-11	3.64	轻载	6091.79	0	扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	4	1675	6091.79
碧荷114线	10	550	D5000维护值	2.15	2021-06-07	0.39	轻载	6630.96	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	4	2690	6630.96
部队114线	10	190	D5000维护值	2.77	2021-04-14	1.46	轻载	2255.58	0	扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	0		2255.58
蔡北121线	10	531	D5000维护值	113.88	2021-06-29	21.45	轻载	4465.44	0	扬州.方桥变/2号主变	32.08	扬州.方桥变/10kV.10千伏III段母线	0		4465.44
蔡桥113线	10	531	D5000维护值	238.8	2021-06-29	44.97	轻载	2301.83	0	扬州.方桥变/1号主变	28.1	扬州.方桥变/10kV.10千伏I段母线	0		2301.83
蔡桥205线	10	531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.新集变/2号主变	7.98	扬州.新集变/10kV.10千伏II段母线	107	31875	6437.84
蚕桑111线	10	531	D5000维护值	90.35	2021-04-01	17.02	轻载	4872.98	0	扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	40	19760	4872.98
曹山135线	10	531	D5000维护值	24.38	2021-06-28	4.59	轻载	6015.58	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏III段母线	7	3940	6015.58

茶场122线	10531	D5000维护值	120.4	2021-04-09	22.67	轻载	4352.52	0	扬州.谢集变/2号主变	20.16	扬州.谢集变/10kV.10千伏II段母线	47	11890	4352.52
长盛112线	10530	D5000维护值	97.54	2021-04-07	18.4	轻载	4736.33	0	扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	76	22153	4736.33
长丝222线	10531	D5000维护值	265.43	2021-06-25	49.99	轻载	1840.6	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	0		1840.6
长兴122线	10531	D5000维护值	84.92	2021-06-25	15.99	轻载	4967.03	0	扬州.月塘变/2号主变	5.43	扬州.月塘变/10kV.10千伏II段母线	68	16230	4967.03
车站132线	10455	D5000维护值	36.84	2021-06-16	8.1	轻载	4878.35	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏III段母线	2	8760	4878.35
陈冲138线	10455	D5000维护值	0	2021-04-01	0	轻载	5516.42	0	扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏III段母线	0		5516.42
陈工117线	10455	D5000维护值	159.65	2021-06-22	35.09	轻载	2751.28	0	扬州.陈集变/1号主变	8.27	扬州.陈集变/10kV.10千伏I段母线	15	6880	2751.28
陈开112线	10531	D5000维护值	265.37	2021-06-30	49.98	轻载	1841.64	0	扬州.陈集变/1号主变	8.27	扬州.陈集变/10kV.10千伏I段母线	14	8390	1841.64
城东121线	10531	D5000维护值	130.98	2021-06-12	24.67	轻载	4169.27	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏II段母线	32	13710	4169.27
城区1号145线	10531	D5000维护值	96.99	2021-05-20	18.27	轻载	4757.98	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏IV段母线	18	6050	4757.98
城区2号144线	10531	D5000维护值	229.15	2021-06-15	43.15	轻载	2468.97	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏IV段母线	35	15665	2468.97
城西1号114线	10531	D5000维护值	139.91	2021-06-15	26.35	轻载	4014.6	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	28	13530	4014.6
城西2号124线	10531	D5000维护值	185.56	2021-06-24	34.95	轻载	3223.94	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	64	27100	3223.94
大陈143线	10531	手工维护值	315.39	2021-05-26	59.4	中载	975.29	0	扬州.大仪变/2号主变	28.76	扬州.大仪变/10kV.10千伏IV段母线	30	10515	975.29
大开128线	10531	手工维护值	108.63	2021-06-23	20.46	轻载	4556.37	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏II段母线	10	6240	4556.37
大庆113线	10531	D5000维护值	92.39	2021-06-15	17.4	轻载	4837.65	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	23	12055	4837.65
大巷111线	10531	手工维护值	299.89	2021-06-12	56.48	中载	1243.75	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏I段母线	79	24465	1243.75

大仪141线	10	531	手工维护值	79.1	2021-06-25	14.9	轻载	5067.83	0	扬州.大仪变/2号主变	28.76	扬州.大仪变/10kV.10千伏IV段母线	19	6720	5067.83
大玉123线	10	531	D5000维护值	75.6	2021-06-12	14.24	轻载	5128.45	0	扬州.月塘变/2号主变	5.43	扬州.月塘变/10kV.10千伏II段母线	54	11010	5128.45
大寨1号136线	10	531	D5000维护值	72.76	2021-05-09	13.7	轻载	5177.64	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏III段母线	28	6090	5177.64
大寨2号146线	10	531	D5000维护值	44.33	2021-06-12	8.35	轻载	5670.05	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏IV段母线	28	6060	5670.05
登月121线	10	531	D5000维护值	71.38	2021-06-24	13.44	轻载	5201.54	0	扬州.月塘变/2号主变	5.43	扬州.月塘变/10kV.10千伏II段母线	23	7940	5201.54
电子管126线	10	150	D5000维护值	0	2021-04-01	0	轻载	1818.6	0	扬州.矿区变/2号主变	4.36	扬州.矿区变/10kV.10千伏II段母线	0		1818.6
东开1号112线	10	531	D5000维护值	159.96	2021-04-03	30.12	轻载	3667.34	0	扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	33	25475	3667.34
东开2号126线	10	550	D5000维护值	332.23	2021-06-15	60.41	中载	913.98	0	扬州.仪征城东变/2号主变	24.9	扬州.仪征城东变/10kV.10千伏II段母线	33	34980	913.98
东门134线	10	531	D5000维护值	101.88	2021-06-04	19.19	轻载	4673.28	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	42	22900	4673.28
东朴1号133线	10	531	D5000维护值	119.4	2021-06-24	22.49	轻载	4369.84	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏III段母线	90	26955	4369.84
东朴2号123线	10	531	D5000维护值	56.64	2021-04-26	10.67	轻载	5456.84	0	江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏II段母线	48	10360	5456.84
东升116线	10	531	D5000维护值	146.6	2021-06-23	27.61	轻载	3898.73	0	扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	78	33905	3898.73
东圩1号114线	10	531	D5000维护值	62.4	2021-06-14	11.75	轻载	5357.08	0	扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	26	18400	5357.08
东圩2号115线	10	531	D5000维护值	106.7	2021-06-30	20.09	轻载	4589.8	0	扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	27	25110	4589.8
东园1号111线	10	531	D5000维护值	154.37	2021-06-07	29.07	轻载	3764.16	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	15	6725	3764.16
东园2号131线	10	531	D5000维护值	152.75	2021-06-02	28.77	轻载	3792.21	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏III段母线	21	10090	3792.21
东岳118线	10	531	D5000维护值	81.22	2021-06-09	15.3	轻载	5031.11	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	0		5031.11

尔富1号125线	10479	D5000维护值	190.46	2021-04-05	39.76	轻载	2508.63	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏II段母线	0		2508.63
尔富2号135线	10479	D5000维护值	1.87	2021-06-20	0.39	轻载	5775.01	0	扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏III段母线	0		5775.01
方新1号115线	10531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.方桥变/1号主变	28.1	扬州.方桥变/10kV.10千伏I段母线	0		6437.84
方新2号133线	10531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.方桥变/2号主变	32.08	扬州.方桥变/10kV.10千伏III段母线	0		6437.84
霏林113线	10531	D5000维护值	345.51	2021-06-28	65.07	中载	453.61	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	21	11340	453.61
冯庄121线	10531	D5000维护值	228.04	2021-06-28	42.95	轻载	2488.19	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏II段母线	59	27335	2488.19
凤仪117线	10531	D5000维护值	99.85	2021-06-02	18.8	轻载	4708.44	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	14	8740	4708.44
富尔114线	10531	D5000维护值	166.51	2021-06-05	31.36	轻载	3553.89	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏I段母线	1	6000	3553.89
钢管124线	10275	D5000维护值	113.27	2021-06-05	41.19	轻载	1372.26	0	扬州.矿区变/2号主变	4.36	扬州.矿区变/10kV.10千伏II段母线	0		1372.26
港服111线	10531	手工维护值	70.02	2021-04-03	13.19	轻载	5225.1	0			扬州.胥南变/10kV.10千伏I段母线	0		5225.1
港务125线	10469	D5000维护值	0	2021-04-01	0	轻载	5686.16	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	0		5686.16
高集121线	10292	D5000维护值	110.32	2021-06-24	37.78	轻载	1629.47	0	扬州.谢集变/2号主变	20.16	扬州.谢集变/10kV.10千伏II段母线	75	16690	1629.47
高所141线	10531	D5000维护值	2.57	2021-05-15	0.48	轻载	6393.33	0	江苏.高集变/3号主变	132.16	江苏.高集变/10kV.10千伏IV段母线	0		6393.33
工农121线	10531	D5000维护值	151.49	2021-06-15	28.53	轻载	3814.04	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	44	17935	3814.04
弓尾127线	10531	D5000维护值	309.7	2021-05-23	58.32	中载	1073.84	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	51	21590	1073.84
公道1号135线	10531	D5000维护值	68.91	2021-04-12	12.98	轻载	5244.32	0	江苏.临湖变/2号主变	78.76	江苏.临湖变/10kV.10千伏III段母线	0		5244.32
公道2号142线	10531	D5000维护值	75.59	2021-04-12	14.24	轻载	5128.63	0	江苏.临湖变/2号主变	78.76	江苏.临湖变/10kV.10千伏IV段母线	0		5128.63

公园114线	10	531	D5000维护值	170.81	2021-06-15	32.17	轻载	3479.41	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏I段母线	36	11355	3479.41
古井142线	10	531	D5000维护值	225.91	2021-04-28	42.54	轻载	2525.08	0	扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏IV段母线	97	24655	2525.08
古湄114线	10	550	手工维护值	96.97	2021-05-26	17.63	轻载	4988.68	0			扬州.胥南变/10kV.10千伏I段母线	19	14800	4988.68
古湄2号137线	10	455	D5000维护值	0	2021-04-01	0	轻载	5516.42	0	扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏III段母线	0		5516.42
古南122线	10	531	D5000维护值	101.82	2021-06-24	19.18	轻载	4674.32	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏II段母线	72	16190	4674.32
光明213线	10	531	D5000维护值	72.68	2021-06-05	13.69	轻载	5179.03	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	4	1295	5179.03
国庆141线	10	531	D5000维护值	269	2021-06-24	50.66	中载	1778.76	0	扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏IV段母线	43	18830	1778.76
国税111线	10	455	D5000维护值	185.63	2021-06-15	40.8	轻载	2301.31	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏I段母线	28	14025	2301.31
海天213线	10	550	D5000维护值	384.98	2021-06-11	70	中载	0.35	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	3	2800	0.35
何巷145线	10	531	D5000维护值	103.19	2021-05-11	19.43	轻载	4650.59	0	江苏.临湖变/2号主变	78.76	江苏.临湖变/10kV.10千伏IV段母线	0		4650.59
河北115线	10	531	手工维护值	91.76	2021-06-10	17.28	轻载	4848.56	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏I段母线	55	16410	4848.56
恒华113线	10	531	D5000维护值	148.81	2021-06-25	28.02	轻载	3860.45	0	扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	25	5185	3860.45
恒基212线	10	531	D5000维护值	202.52	2021-06-29	38.14	轻载	2930.2	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	4	3550	2930.2
红旗1号123线	10	531	D5000维护值	158.38	2021-06-12	29.83	轻载	3694.7	0	扬州.仪征城东变/2号主变	24.9	扬州.仪征城东变/10kV.10千伏II段母线	38	34775	3694.7
红心117线	10	530	D5000维护值	0.06	2021-06-29	0.01	轻载	6424.68	0	扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	0		6424.68
洪震147线	10	455	D5000维护值	0	2021-04-01	0	轻载	5516.42	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏IV段母线	0		5516.42
虹桥115线	10	531	D5000维护值	130.52	2021-05-11	24.58	轻载	4177.24	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	9	6845	4177.24

花园112线	10531	D5000维护值	126	2021-06-23	23.73	轻载	4255.52	0	扬州.方桥变/1号主变	28.1	扬州.方桥变/10kV.10千伏I段母线	0		4255.52
花园1号131线	10531	D5000维护值	85.2	2021-06-14	16.05	轻载	4962.18	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏III段母线	34	28040	4962.18
花园201线	10531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.新集变/1号主变	7.98	扬州.新集变/10kV.10千伏I段母线	89	32665	6437.84
花园2号141线	10531	D5000维护值	42	2021-06-03	7.91	轻载	5710.4	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏IV段母线	10	6090	5710.4
华德132线	10531	手工维护值	20.81	2021-04-28	3.92	轻载	6077.41	0	扬州.大仪变/2号主变	28.76	扬州.大仪变/10kV.10千伏III段母线	0		6077.41
华利131线	10455	D5000维护值	2.28	2021-06-01	0.5	轻载	5476.93	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏III段母线	1	5700	5476.93
华利2号143线	10455	D5000维护值	1.56	2021-04-30	0.34	轻载	5489.4	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏IV段母线	1	5700	5489.4
华侨211线	10531	D5000维护值	160.66	2021-06-15	30.26	轻载	3655.21	0	扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	27	19235	3655.21
华泰146线	10550	手工维护值	34.82	2021-06-23	6.33	轻载	6065.12	0	扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏IV段母线	0		6065.12
华兴132线	10455	D5000维护值	103.42	2021-06-09	22.73	轻载	3725.19	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏III段母线	11	6470	3725.19
华耀147线	10455	D5000维护值	0	2021-04-01	0	轻载	5516.42	0	扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏IV段母线	0		5516.42
画舫1号135线	10531	D5000维护值	35.92	2021-06-30	6.76	轻载	5815.71	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏III段母线	38	8200	5815.71
画舫2号145线	10531	D5000维护值	238.46	2021-06-30	44.91	轻载	2307.72	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏IV段母线	58	14210	2307.72
汇元1号125线	10531	D5000维护值	37.57	2021-06-24	7.08	轻载	5787.13	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	12	9210	5787.13
建军123线	10531	D5000维护值	179	2021-06-28	33.71	轻载	3337.56	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏II段母线	53	21385	3337.56
建中143线	10531	D5000维护值	85.58	2021-06-10	16.12	轻载	4955.6	0	扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏IV段母线	109	33750	4955.6
江边135线	10531	D5000维护值	60.84	2021-05-26	11.46	轻载	5384.1	0	扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏III段母线	1	630	5384.1

江海115线	10	531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏I段母线	0		6437.84
江南131线	10	550	D5000维护值	13.24	2021-06-13	2.41	轻载	6438.88	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏III段母线	0		6438.88
江扬124线	10	531	D5000维护值	110.74	2021-06-25	20.85	轻载	4519.83	0	扬州.谢集变/2号主变	20.16	扬州.谢集变/10kV.10千伏II段母线	10	7190	4519.83
金龙132线	10	550	D5000维护值	1.06	2021-06-10	0.19	轻载	6649.84	0	扬州.金马变/2号主变	30.83	扬州.金马变/10kV.10千伏III段母线	0		6649.84
金石113线	10	530	D5000维护值	40.11	2021-04-06	7.57	轻载	5731.01	0	扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	21	5885	5731.01
金营1号115线	10	531	D5000维护值	85.82	2021-06-30	16.16	轻载	4951.44	0	扬州.金马变/1号主变	23.74	扬州.金马变/10kV.10千伏I段母线	26	5585	4951.44
金营2号116线	10	531	D5000维护值	187.47	2021-04-16	35.31	轻载	3190.86	0	扬州.金马变/1号主变	23.74	扬州.金马变/10kV.10千伏I段母线	40	13300	3190.86
金庄115线	10	531	D5000维护值	126.5	2021-04-04	23.82	轻载	4246.86	0	扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	60	17535	4246.86
晶藏127线	10	531	D5000维护值	98.09	2021-06-29	18.47	轻载	4738.93	0	扬州.仪征城东变/2号主变	24.9	扬州.仪征城东变/10kV.10千伏II段母线	0		4738.93
镜城124线	10	531	D5000维护值	116.15	2021-06-12	21.87	轻载	4426.13	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	40	23695	4426.13
镜湖1号123线	10	531	D5000维护值	191.03	2021-06-29	35.98	轻载	3129.2	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	13	6650	3129.2
镜湖东112线	10	531	D5000维护值	161.18	2021-06-11	30.35	轻载	3646.21	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	45	23895	3646.21
镜湖西122线	10	531	D5000维护值	115.73	2021-06-15	21.79	轻载	4433.4	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	42	19580	4433.4
镜南119线	10	531	D5000维护值	212.96	2021-06-14	40.11	轻载	2749.38	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	53	33430	2749.38
军民111线	10	530	D5000维护值	89.66	2021-06-25	16.92	轻载	4872.81	0	扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	67	17940	4872.81
军西121线	10	530	D5000维护值	0.07	2021-06-21	0.01	轻载	6424.51	0	扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		6424.51
开东1号115线	10	459	D5000维护值	97.73	2021-06-25	21.29	轻载	3872.23	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	15	7675	3872.23

开东2号116线	10459	D5000维护值	99.47	2021-06-11	21.67	轻载	3842.10		扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	14	8090	3842.10
开发127线	10531	手工维护值	152.58	2021-04-23	28.73	轻载	3795.16		扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏II段母线	14	6275	3795.16
康民141线	10531	D5000维护值	159.57	2021-06-30	30.05	轻载	3674.09		扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏IV段母线	0		3674.09
康养222线	10531	D5000维护值	40.43	2021-06-29	7.61	轻载	5737.60		扬州.谢集变/2号主变	20.16	扬州.谢集变/10kV.10千伏II段母线	0		5737.60
空军125线	10455	D5000维护值	138.70	2021-06-14	30.48	轻载	3114.14		扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏II段母线	27	13865	3114.14
矿街115线	10400	D5000维护值	143.39	2021-06-30	35.85	轻载	2366.09		扬州.矿区变/1号主变	5.65	扬州.矿区变/10kV.10千伏I段母线	51	17935	2366.09
蓝井145线	10455	D5000维护值	0	2021-04-01	0	轻载	5516.42		扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏IV段母线	0		5516.42
黎明124线	10550	D5000维护值	98.68	2021-06-15	17.94	轻载	4959.06		扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏II段母线	18	9480	4959.06
李家118线	10530	D5000维护值	0.1	2021-04-04	0.02	轻载	6423.99		扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	0		6423.99
李林139线	10455	D5000维护值	0	2021-04-01	0	轻载	5516.42		扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏III段母线	0		5516.42
李云111线	10531	D5000维护值	56.1	2021-06-24	10.56	轻载	5466.19		江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏I段母线	124	31430	5466.19
联合1号115线	10531	D5000维护值	0	2021-04-01	0	轻载	6437.84		扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏I段母线	0		6437.84
粮库133线	10455	D5000维护值	88.77	2021-06-15	19.51	轻载	3978.92		扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏III段母线	12	4940	3978.92
林果118线	10531	D5000维护值	51.68	2021-06-30	9.73	轻载	5542.75		扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	21	8035	5542.75
零部1号121线	10531	D5000维护值	46.76	2021-04-09	8.81	轻载	5627.96		扬州.仪征城东变/2号主变	24.9	扬州.仪征城东变/10kV.10千伏II段母线	15	11855	5627.96
零部2号122线	10531	D5000维护值	2.11	2021-06-30	0.4	轻载	6401.30		扬州.仪征城东变/2号主变	24.9	扬州.仪征城东变/10kV.10千伏II段母线	0		6401.30
龙湖131线	10531	D5000维护值	28.26	2021-04-03	5.32	轻载	5948.38		扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏III段母线	26	12560	5948.38

龙开1号111线	10	531	D5000维护值	107.64	2021-06-03	20.27	轻载	4573.52	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏I段母线	123	25260	4573.52
龙开2号121线	10	531	D5000维护值	112.68	2021-06-11	21.22	轻载	4486.23	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏II段母线	124	29475	4486.23
路东144线	10	531	手工维护值	160.92	2021-06-11	30.31	轻载	3650.71	0	扬州.大仪变/2号主变	28.76	扬州.大仪变/10kV.10千伏IV段母线	27	8310	3650.71
路南124线	10	455	D5000维护值	0	2021-04-01	0	轻载	5516.42	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏II段母线	0		5516.42
马东122线	10	531	D5000维护值	97.43	2021-06-24	18.35	轻载	4750.36	0	扬州.金马变/2号主变	30.83	扬州.金马变/10kV.10千伏II段母线	103	21780	4750.36
马开1号111线	10	531	D5000维护值	87.23	2021-05-04	16.43	轻载	4927.02	0	扬州.金马变/1号主变	23.74	扬州.金马变/10kV.10千伏I段母线	53	16140	4927.02
马开2号112线	10	531	D5000维护值	63.31	2021-04-24	11.92	轻载	5341.31	0	扬州.金马变/1号主变	23.74	扬州.金马变/10kV.10千伏I段母线	36	15825	5341.31
马南113线	10	531	D5000维护值	146.32	2021-06-25	27.56	轻载	3903.58	0	扬州.金马变/1号主变	23.74	扬州.金马变/10kV.10千伏I段母线	68	19715	3903.58
马桥131线	10	531	D5000维护值	52.67	2021-06-03	9.92	轻载	5525.6	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	23	7225	5525.6
马西114线	10	531	D5000维护值	54.17	2021-06-11	10.2	轻载	5499.62	0	扬州.金马变/1号主变	23.74	扬州.金马变/10kV.10千伏I段母线	50	9870	5499.62
毛桥135线	10	531	D5000维护值	154.8	2021-05-25	29.15	轻载	3756.71	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏III段母线	34	9035	3756.71
米厂113线	10	531	D5000维护值	164.65	2021-06-29	31.01	轻载	3586.11	0	扬州.陈集变/1号主变	8.27	扬州.陈集变/10kV.10千伏I段母线	85	34260	3586.11
闽开1号113线	10	550	D5000维护值	296.63	2021-06-09	53.93	中载	1530.57	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	45	21770	1530.57
闽开2号121线	10	550	D5000维护值	58.07	2021-05-24	10.56	轻载	5662.43	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	14	10850	5662.43
闽泰114线	10	531	D5000维护值	22.73	2021-06-30	4.28	轻载	6044.16	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	7	5430	6044.16
明岐1号123线	10	531	D5000维护值	0.22	2021-05-05	0.04	轻载	6434.03	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏II段母线	0		6434.03
明岐2号124线	10	531	D5000维护值	0.04	2021-05-17	0.01	轻载	6437.15	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏II段母线	0		6437.15

南站133线	10	530	D5000维护值	48.33	2021-06-15	9.12	轻载	5588.64	0	扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		5588.64
农林144线	10	455	D5000维护值	0	2021-04-01	0	轻载	5516.42	0	扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏IV段母线	0		5516.42
农桥136线	10	455	D5000维护值	71.4	2021-04-27	15.69	轻载	4279.77	0	扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏III段母线	0		4279.77
暖山1号124线	10	531	D5000维护值	2.96	2021-04-10	0.56	轻载	6386.58	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏II段母线	0		6386.58
暖山2号144线	10	479	D5000维护值	51.52	2021-06-11	10.76	轻载	4915.07	0	扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏IV段母线	10	6750	4915.07
盘开1号112线	10	531	D5000维护值	196.04	2021-06-14	36.92	轻载	3042.43	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏I段母线	130	43340	3042.43
盘开2号132线	10	531	D5000维护值	286.27	2021-05-20	53.91	中载	1479.65	0	扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏III段母线	1	6000	1479.65
盘新113线	10	479	D5000维护值	2.68	2021-04-10	0.56	轻载	5760.98	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏I段母线	17	5195	5760.98
盘扬1号133线	10	531	D5000维护值	409.52	2021-06-24	77.12	重载	0	0	扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏III段母线	46	14795	0
盘扬2号121线	10	531	D5000维护值	136.9	2021-06-30	25.78	轻载	4066.74	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏II段母线	35	9825	4066.74
蒲薪124线	10	531	D5000维护值	256.29	2021-04-14	48.27	轻载	1998.9	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏II段母线	23	7930	1998.9
朴席1号111线	10	531	D5000维护值	32.51	2021-06-29	6.12	轻载	5874.77	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏I段母线	34	6755	5874.77
朴席2号125线	10	531	D5000维护值	44.05	2021-06-30	8.3	轻载	5674.9	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏II段母线	9	2100	5674.9
浦东118线	10	531	D5000维护值	198.08	2021-06-30	37.3	轻载	3007.1	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	16	8155	3007.1
浦环127线	10	531	D5000维护值	234.83	2021-04-04	44.22	轻载	2370.59	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	31	18095	2370.59
浦环2号211线	10	531	D5000维护值	137.6	2021-06-28	25.91	轻载	4054.61	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	9	7920	4054.61
浦开111线	10	469	D5000维护值	245.64	2021-05-12	52.38	中载	1431.67	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	26	10070	1431.67

浦矿221线	10531	D5000维护值	308.02	2021-06-23	58.01	中载	1102.94	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	16	9400	1102.94
浦南129线	10531	D5000维护值	193.3	2021-04-01	36.4	轻载	3089.89	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	42	13315	3089.89
七星126线	10530	D5000维护值	190.29	2021-06-30	35.9	轻载	3129.9	0	扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		3129.9
汽车126线	10531	手工维护值	223.06	2021-06-10	42.01	轻载	2574.44	0	扬州.陈集变/2号主变	10.25	扬州.陈集变/10kV.10千伏II段母线	11	6120	2574.44
汽服141线	10455	D5000维护值	1.44	2021-04-30	0.32	轻载	5491.48	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏IV段母线	0		5491.48
汽开1号113线	10531	D5000维护值	157.86	2021-05-26	29.73	轻载	3703.71	0	江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏I段母线	34	8925	3703.71
汽开2号134线	10531	D5000维护值	178.8	2021-06-28	33.67	轻载	3341.03	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏III段母线	4	1750	3341.03
前程124线	10455	D5000维护值	85.55	2021-06-22	18.8	轻载	4034.69	0			扬州.胥南变/10kV.10千伏II段母线	0		4034.69
前进123线	10530	D5000维护值	0.06	2021-06-26	0.01	轻载	6424.68	0	扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		6424.68
前进126线	10531	D5000维护值	94.33	2021-06-26	17.76	轻载	4804.05	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	17	15270	4804.05
桥南136线	10531	D5000维护值	79.87	2021-04-14	15.04	轻载	5054.5	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	20	9320	5054.5
青年111线	10400	D5000维护值	57.53	2021-04-30	14.38	轻载	3853.18	0	扬州.陈集变/1号主变	8.27	扬州.陈集变/10kV.10千伏I段母线	23	5130	3853.18
清风113线	10550	D5000维护值	126.86	2021-06-14	23.07	轻载	4470.98	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏I段母线	25	13485	4470.98
清水214线	10531	D5000维护值	113.33	2021-06-30	21.34	轻载	4474.97	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	110	33955	4474.97
人民123线	10455	D5000维护值	110.32	2021-06-30	24.25	轻载	3605.68	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏II段母线	24	9845	3605.68
日环125线	10531	D5000维护值	58.93	2021-06-21	11.1	轻载	5417.18	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏II段母线	0		5417.18
荣威132线	10531	D5000维护值	222.74	2021-06-19	41.95	轻载	2579.99	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏III段母线	10	10960	2579.99

瑞福123线	10	550	D5000维护值	5.98	2021-06-29	1.09	轻载	6564.63	0	扬州.金马变/2号主变	30.83	扬州.金马变/10kV.10千伏II段母线	5	4000	6564.63
瑞盛1号125线	10	455	D5000维护值	0	2021-04-01	0	轻载	5516.42	0	扬州.胥南变/1号主变	12.91	扬州.胥南变/10kV.10千伏II段母线	0		5516.42
三东1号132线	10	531	D5000维护值	24.38	2021-06-08	4.59	轻载	6015.58	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏III段母线	2	3060	6015.58
三东2号142线	10	531	D5000维护值	128.51	2021-06-30	24.2	轻载	4212.05	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏IV段母线	1	10000	4212.05
三将117线	10	409	D5000维护值	115.31	2021-05-21	28.19	轻载	2961.55	0	扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	18	7700	2961.55
三联1号112线	10	531	D5000维护值	56.6	2021-06-15	10.66	轻载	5457.53	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏I段母线	23	6255	5457.53
三联2号126线	10	531	D5000维护值	19.25	2021-06-23	3.63	轻载	6104.43	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏II段母线	28	6185	6104.43
三茅111线	10	531	D5000维护值	189.48	2021-06-12	35.68	轻载	3156.05	0	扬州.方桥变/1号主变	28.1	扬州.方桥变/10kV.10千伏I段母线	0		3156.05
三南122线	10	469	D5000维护值	309.81	2021-04-03	66.06	中载	320.25	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	1	10000	320.25
三升1号133线	10	455	D5000维护值	0	2021-04-01	0	轻载	5516.42	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏III段母线	0		5516.42
三升2号143线	10	455	D5000维护值	52.44	2021-06-15	11.53	轻载	4608.16	0	扬州.三益变/3号主变	27.14	扬州.三益变/10kV.10千伏IV段母线	1	10000	4608.16
桑园141线	10	469	D5000维护值	89.03	2021-06-15	18.98	轻载	4144.16	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏IV段母线	20	8170	4144.16
沙集125线	10	400	D5000维护值	151.22	2021-06-22	37.8	轻载	2230.47	0	扬州.陈集变/2号主变	10.25	扬州.陈集变/10kV.10千伏II段母线	96	21315	2230.47
商贸116线	10	531	D5000维护值	1.85	2021-05-16	0.35	轻载	6405.8	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	0		6405.8
上开1号143线	10	531	D5000维护值	103.8	2021-04-13	19.55	轻载	4640.03	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏IV段母线	10	5450	4640.03
上开2号144线	10	531	D5000维护值	46.2	2021-05-10	8.7	轻载	5637.66	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏IV段母线	11	8415	5637.66
上余124线	10	530	D5000维护值	0.07	2021-06-16	0.01	轻载	6424.51	0	扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		6424.51

生北116线	10	550	D5000维护值	490.96	2021-06-09	89.27	重载	0	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	35	27610	0
生开1号115线	10	550	D5000维护值	182	2021-06-30	33.09	轻载	3515.96	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	28	22720	3515.96
生开2号121线	10	550	D5000维护值	189.71	2021-06-24	34.49	轻载	3382.42	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	31	31370	3382.42
生南117线	10	550	D5000维护值	119.85	2021-05-10	21.79	轻载	4592.4	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	14	12315	4592.4
生态114线	10	530	D5000维护值	0.06	2021-06-27	0.01	轻载	6424.68	0	扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	0		6424.68
圣塘144线	10	531	D5000维护值	215.86	2021-06-10	40.65	轻载	2699.15	0	江苏.临湖变/2号主变	78.76	江苏.临湖变/10kV.10千伏IV段母线	108	27660	2699.15
石桥146线	10	531	D5000维护值	170.25	2021-06-30	32.06	轻载	3489.11	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏IV段母线	55	23260	3489.11
时代123线	10	531	D5000维护值	358.77	2021-05-26	67.56	中载	223.95	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏II段母线	15	7825	223.95
世博135线	10	530	D5000维护值	0.06	2021-06-26	0.01	轻载	6424.68	0	扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		6424.68
双涧145线	10	531	手工维护值	299.27	2021-04-30	56.36	中载	1254.49	0	扬州.大仪变/2号主变	28.76	扬州.大仪变/10kV.10千伏IV段母线	75	20925	1254.49
双塘142线	10	531	手工维护值	113.14	2021-06-22	21.31	轻载	4478.26	0	扬州.大仪变/2号主变	28.76	扬州.大仪变/10kV.10千伏IV段母线	77	17765	4478.26
水厂133线	10	531	D5000维护值	85.37	2021-06-24	16.08	轻载	4959.24	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	16	7060	4959.24
水务113线	10	531	手工维护值	106.35	2021-04-02	20.03	轻载	4595.86	0			扬州.晋南变/10kV.10千伏I段母线	8	5585	4595.86
舜天1号119线	10	531	D5000维护值	150.34	2021-04-07	28.31	轻载	3833.96	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	0		3833.96
舜天2号211线	10	531	D5000维护值	88.66	2021-04-17	16.7	轻载	4902.25	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	0		4902.25
四庄116线	10	531	D5000维护值	36.74	2021-05-19	6.92	轻载	5801.51	0	扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	20	6230	5801.51
苏云112线	10	531	D5000维护值	109.92	2021-06-30	20.7	轻载	4534.03	0	扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	48	19990	4534.03

塔山124线	10	531	D5000维护值	220.76	2021-06-28	41.57	轻载	2614.28	0	扬州.陈集变/2号主变	10.25	扬州.陈集变/10kV.10千伏II段母线	109	25920	2614.28
塔影206线	10	531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.新集变/2号主变	7.98	扬州.新集变/10kV.10千伏II段母线	19	9900	6437.84
桃坞125线	10	531	D5000维护值	300	2021-06-23	56.5	中载	1241.84	0	江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏II段母线	74	20390	1241.84
体育131线	10	455	D5000维护值	13.5	2021-04-05	2.97	轻载	5282.6	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏III段母线	1	630	5282.6
天安145线	10	531	D5000维护值	150.6	2021-06-08	28.36	轻载	3829.45	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏IV段母线	48	11740	3829.45
天保128线	10	469	D5000维护值	0	2021-04-01	0	轻载	5686.16	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	14	7145	5686.16
天富111线	10	531	D5000维护值	516.7	2021-06-30	97.31	重载	0	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏I段母线	0		0
天龙134线	10	531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.盘古变/3号主变	24.52	扬州.盘古变/10kV.10千伏III段母线	1	4500	6437.84
天宁111线	10	531	D5000维护值	134.64	2021-06-15	25.36	轻载	4105.88	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	44	16685	4105.88
天祥114线	10	531	D5000维护值	109.02	2021-04-01	20.53	轻载	4549.62	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏I段母线	2	2715	4549.62
铜山136线	10	469	D5000维护值	237.46	2021-04-25	50.63	中载	1573.35	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏III段母线	38	16760	1573.35
凸轮1号119线	10	469	D5000维护值	322.11	2021-04-20	68.68	中载	107.21	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	5	2615	107.21
凸轮2号211线	10	469	D5000维护值	125.35	2021-06-16	26.73	轻载	3515.09	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	0		3515.09
外滩122线	10	531	D5000维护值	130.98	2021-06-24	24.67	轻载	4169.27	0	扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏II段母线	26	9380	4169.27
万集113线	10	531	手工维护值	68.91	2021-06-07	12.98	轻载	5244.32	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏I段母线	65	14050	5244.32
王云121线	10	531	D5000维护值	105.9	2021-06-30	19.94	轻载	4603.66	0	江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏II段母线	12	7865	4603.66
王庄117线	10	531	D5000维护值	0.77	2021-05-10	0.15	轻载	6424.51	0	扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	0		6424.51

威富126线	10	531	D5000维护值	222.58	2021-05-14	41.92	轻载	2582.76	0	扬州.盘古变/1号主变	20.17	扬州.盘古变/10kV.10千伏II段母线	1	9000	2582.76
微波122线	10	531	D5000维护值	36.31	2021-06-15	6.84	轻载	5808.95	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏II段母线	2	830	5808.95
圩东1号123线	10	531	D5000维护值	370.55	2021-06-30	69.78	中载	19.92	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	86	54140	19.92
圩东2号124线	10	531	D5000维护值	209.99	2021-06-25	39.55	轻载	2800.82	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	49	18985	2800.82
圩街126线	10	531	D5000维护值	228.47	2021-06-25	43.03	轻载	2480.74	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	25	13035	2480.74
圩开1号111线	10	459	D5000维护值	113.38	2021-04-22	24.7	轻载	3601.17	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	5	14040	3601.17
圩开2号112线	10	531	D5000维护值	62.51	2021-06-24	11.77	轻载	5355.17	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	9	4130	5355.17
乌山113线	10	531	D5000维护值	107.6	2021-06-29	20.26	轻载	4574.21	0	扬州.月塘变/1号主变	6.09	扬州.月塘变/10kV.10千伏I段母线	99	20280	4574.21
五星131线	10	531	手工维护值	90.28	2021-04-28	17	轻载	4874.19	0	扬州.大仪变/2号主变	28.76	扬州.大仪变/10kV.10千伏III段母线	26	5215	4874.19
五一111线	10	531	D5000维护值	112.35	2021-06-16	21.16	轻载	4491.94	0	扬州.月塘变/1号主变	6.09	扬州.月塘变/10kV.10千伏I段母线	56	13430	4491.94
五一124线	10	531	D5000维护值	37.27	2021-06-15	7.02	轻载	5792.33	0	扬州.仪征城东变/2号主变	24.9	扬州.仪征城东变/10kV.10千伏II段母线	10	6275	5792.33
五一2号129线	10	531	D5000维护值	139.92	2021-05-15	26.35	轻载	4014.43	0	扬州.仪征城东变/2号主变	24.9	扬州.仪征城东变/10kV.10千伏II段母线	11	14910	4014.43
西环114线	10	550	D5000维护值	84.66	2021-05-10	15.39	轻载	5201.89	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	0		5201.89
西园1号115线	10	531	D5000维护值	197.3	2021-06-15	37.16	轻载	3020.61	0	扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	75	24815	3020.61
西园2号133线	10	531	D5000维护值	106.57	2021-06-15	20.07	轻载	4592.05	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏III段母线	3	4350	4592.05
下余125线	10	530	D5000维护值	0.07	2021-06-18	0.01	轻载	6424.51	0	扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		6424.51
先锋122线	10	455	D5000维护值	92.51	2021-06-30	20.33	轻载	3914.15	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	35	16890	3914.15

纤北134线	10	531	D5000维护值	135.37	2021-06-03	25.49	轻载	4093.24	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏III段母线	17	10995	4093.24
香沟114线	10	531	手工维护值	178.24	2021-06-24	33.57	轻载	3350.73	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏I段母线	76	26710	3350.73
小集213线	10	530	D5000维护值	251.97	2021-04-07	47.54	轻载	2061.6	0	扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	0		2061.6
肖北234线	10	455	D5000维护值	155.35	2021-04-12	34.14	轻载	2825.76	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/10kV.10千伏III段母线	60	15915	2825.76
肖东233线	10	455	D5000维护值	207.23	2021-05-26	45.55	轻载	1927.2	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/10kV.10千伏III段母线	18	8790	1927.2
谢集123线	10	531	D5000维护值	154.66	2021-05-06	29.13	轻载	3759.13	0	扬州.谢集变/2号主变	20.16	扬州.谢集变/10kV.10千伏II段母线	111	27490	3759.13
新安135线	10	531	D5000维护值	59.76	2021-06-29	11.25	轻载	5402.8	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	12	11770	5402.8
新北132线	10	531	D5000维护值	43.8	2021-06-01	8.25	轻载	5679.23	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏III段母线	12	8365	5679.23
新城142线	10	531	D5000维护值	125.02	2021-06-15	23.54	轻载	4272.5	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏IV段母线	41	27195	4272.5
新东1号112线	10	531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏I段母线	0		6437.84
新东2号122线	10	531	D5000维护值	36.9	2021-04-12	6.95	轻载	5798.74	0	江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏II段母线	1	10000	5798.74
新光118线	10	459	D5000维护值	105.47	2021-06-24	22.98	轻载	3738.18	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	0		3738.18
新河117线	10	531	D5000维护值	138.08	2021-06-25	26	轻载	4046.3	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	0		4046.3
新华142线	10	531	D5000维护值	370.8	2021-04-29	69.83	中载	15.59	0	江苏.新东变/2号主变	70.42	江苏.新东变/10kV.10千伏IV段母线	39	13095	15.59
新集122线	10	531	D5000维护值	339.48	2021-06-24	63.93	中载	558.05	0	扬州.方桥变/2号主变	32.08	扬州.方桥变/10kV.10千伏III段母线	0		558.05
新集204线	10	531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.新集变/2号主变	7.98	扬州.新集变/10kV.10千伏II段母线	5	3415	6437.84
新街119线	10	531	D5000维护值	156.09	2021-06-30	29.4	轻载	3734.37	0	扬州.仪征城东变/1号主变	21.75	扬州.仪征城东变/10kV.10千伏I段母线	52	21685	3734.37

新能121线	10	550	手工维护值	0	2021-04-01	0	轻载	6668.2	0			扬州.胥南变/10kV.10千伏II段母线	0		6668.2
新升1号114线	10	531	D5000维护值	24	2021-06-23	4.52	轻载	6022.16	0	江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏I段母线	1	2860	6022.16
新升2号124线	10	531	D5000维护值	114.72	2021-06-30	21.6	轻载	4450.89	0	江苏.新东变/1号主变	68.86	江苏.新东变/10kV.10千伏II段母线	1	10000	4450.89
新中114线	10	531	D5000维护值	339	2021-05-06	63.84	中载	566.36	0	扬州.方桥变/1号主变	28.1	扬州.方桥变/10kV.10千伏I段母线	0		566.36
新中203线	10	531	D5000维护值	0	2021-04-01	0	轻载	6437.84	0	扬州.新集变/1号主变	7.98	扬州.新集变/10kV.10千伏I段母线	20	8915	6437.84
胥东1号164线	10	531	手工维护值	154.69	2021-05-12	29.13	轻载	3758.61	0	扬州.胥南变/1号主变	12.91	扬州.胥南变/10kV.10千伏VI段母线	36	17915	3758.61
胥东2号165线	10	531	手工维护值	232.32	2021-05-27	43.75	轻载	2414.06	0	扬州.胥南变/1号主变	12.91	扬州.胥南变/10kV.10千伏VI段母线	36	22055	2414.06
胥工115线	10	531	手工维护值	370.31	2021-05-08	69.74	中载	24.07	0			扬州.胥南变/10kV.10千伏I段母线	52	23915	24.07
胥矿122线	10	531	手工维护值	54.2	2021-05-04	10.21	轻载	5499.1	0			扬州.胥南变/10kV.10千伏II段母线	10	2140	5499.1
胥浦122线	10	455	D5000维护值	80.67	2021-06-15	17.73	轻载	4119.22	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏II段母线	27	12620	4119.22
胥西1号125线	10	531	D5000维护值	9.82	2021-06-14	1.85	轻载	6267.76	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	3	1200	6267.76
胥西2号126线	10	531	D5000维护值	122.74	2021-06-24	23.11	轻载	4311.99	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	52	18065	4311.99
胥肖123线	10	531	手工维护值	115.72	2021-05-18	21.79	轻载	4433.57	0			扬州.胥南变/10kV.10千伏II段母线	6	6090	4433.57
胥云118线	10	531	D5000维护值	166.02	2021-06-25	31.27	轻载	3562.38	0	扬州.金马变/1号主变	23.74	扬州.金马变/10kV.10千伏I段母线	66	21015	3562.38
学军112线	10	455	D5000维护值	172.02	2021-06-24	37.81	轻载	2537.03	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏I段母线	34	11230	2537.03
延丰142线	10	550	D5000维护值	184.2	2021-06-22	33.49	轻载	3477.86	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏IV段母线	0		3477.86
沿河117线	10	459	D5000维护值	221.26	2021-06-18	48.2	轻载	1732.69	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	28	16570	1732.69

扬西119线	10	531	D5000维护值	141.6	2021-05-26	26.67	轻载	3985.33	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	24	17400	3985.33
扬子211线	10	531	D5000维护值	104.64	2021-05-27	19.71	轻载	4625.48	0	扬州.城南变/1号主变	32.74	扬州.城南变/10kV.10千伏I段母线	6	3250	4625.48
养老119线	10	531	D5000维护值	46.17	2021-06-26	8.69	轻载	5638.18	0	扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	8	6060	5638.18
耀皮129线	10	531	D5000维护值	315.22	2021-04-12	59.36	中载	978.23	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	2	7815	978.23
耀皮2号213线	10	531	D5000维护值	265.3	2021-05-23	49.96	轻载	1842.85	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	0		1842.85
冶炼114线	10	400	D5000维护值	0	2021-04-01	0	轻载	4849.6	0	扬州.矿区变/1号主变	5.65	扬州.矿区变/10kV.10千伏I段母线	1	30	4849.6
野山131线	10	530	D5000维护值	102.36	2021-04-09	19.31	轻载	4652.84	0	扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	21	7030	4652.84
一洲123线	10	531	D5000维护值	221.7	2021-06-15	41.75	轻载	2598	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	59	21930	2598
依利221线	10	531	D5000维护值	469.53	2021-05-15	88.42	重载	0	0	扬州.圩区变/2号主变	20.33	扬州.圩区变/10kV.10千伏II段母线	1	2500	0
仪寿1号122线	10	531	手工维护值	179.3	2021-06-29	33.77	轻载	3332.37	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏II段母线	100	24160	3332.37
仪寿2号123线	10	531	手工维护值	179.65	2021-06-08	33.83	轻载	3326.31	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏II段母线	91	19995	3326.31
怡人1号112线	10	531	D5000维护值	254.95	2021-06-28	48.01	轻载	2022.11	0	扬州.浦西变/1号主变	18.17	扬州.浦西变/10kV.10千伏I段母线	0		2022.11
怡人2号128线	10	531	D5000维护值	217.2	2021-06-30	40.9	轻载	2675.94	0	扬州.浦西变/2号主变	25.46	扬州.浦西变/10kV.10千伏II段母线	0		2675.94
屹丰133线	10	455	D5000维护值	227.16	2021-05-22	49.93	轻载	1582.01	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏III段母线	1	1600	1582.01
尹山111线	10	531	D5000维护值	262.45	2021-04-12	49.43	轻载	1892.21	0	扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	69	33645	1892.21
荧光1号111线	10	275	手工维护值	0	2021-04-01	0	轻载	3334.1	0	扬州.矿区变/1号主变	5.65	扬州.矿区变/10kV.10千伏I段母线	0		3334.1
荧光2号125线	10	531	手工维护值	105.95	2021-05-18	19.95	轻载	4602.79	0	扬州.矿区变/2号主变	4.36	扬州.矿区变/10kV.10千伏II段母线	26	12400	4360

油田143线	10	531	D5000维护值	69.79	2021-05-19	13.14	轻载	5229.08	0	江苏.临湖变/2号主变	78.76	江苏.临湖变/10kV.10千伏IV段母线	0		5229.08
郁部1号114线	10	531	D5000维护值	69.24	2021-04-26	13.04	轻载	5238.61	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏I段母线	5	6550	5238.61
郁部2号124线	10	531	D5000维护值	134.88	2021-05-20	25.4	轻载	4101.72	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏II段母线	16	14640	4101.72
郁城1号136线	10	455	D5000维护值	108.12	2021-05-06	23.76	轻载	3643.78	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏III段母线	3	5680	3643.78
郁城2号146线	10	455	D5000维护值	140.04	2021-06-09	30.78	轻载	3090.93	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏IV段母线	2	3700	3090.93
郁东1号134线	10	455	D5000维护值	155.28	2021-05-02	34.13	轻载	2826.97	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏III段母线	6	3715	2826.97
郁东2号144线	10	455	D5000维护值	118.8	2021-06-15	26.11	轻载	3458.8	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏IV段母线	1	400	3458.8
郁果145线	10	455	D5000维护值	77.76	2021-04-19	17.09	轻载	4169.62	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏IV段母线	0		4169.62
郁河126线	10	455	D5000维护值	103.8	2021-06-24	22.81	轻载	3718.6	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏II段母线	54	13920	3718.6
郁林135线	10	531	D5000维护值	301.56	2021-04-01	56.79	中载	1214.82	0	扬州.郁桥变/3号主变	18.71	扬州.郁桥变/10kV.10千伏III段母线	35	11935	1214.82
郁零1号113线	10	531	D5000维护值	160.32	2021-06-28	30.19	轻载	3661.1	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏I段母线	11	9260	3661.1
郁零2号123线	10	531	D5000维护值	126.12	2021-06-25	23.75	轻载	4253.45	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏II段母线	6	3915	4253.45
郁龙116线	10	531	D5000维护值	42.84	2021-06-15	8.07	轻载	5695.86	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏I段母线	40	8510	5695.86
郁西1号112线	10	531	D5000维护值	46.32	2021-06-25	8.72	轻载	5635.58	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏I段母线	1	315	5635.58
郁西2号122线	10	531	D5000维护值	143.28	2021-06-02	26.98	轻载	3956.23	0	扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏II段母线	0		3956.23
御景128线	10	550	D5000维护值	67.85	2021-06-11	12.34	轻载	5493.04	0	扬州.仪征城东变/2号主变	24.9	扬州.仪征城东变/10kV.10千伏II段母线	10	10520	5493.04
园北132线	10	531	D5000维护值	27.48	2021-06-13	5.18	轻载	5961.89	0	扬州.方桥变/2号主变	32.08	扬州.方桥变/10kV.10千伏III段母线	0		5961.89

园东113线	10531	D5000维护值	136.96	2021-05-14	25.79	轻载	4065.70		扬州.曹山变/1号主变	13.27	扬州.曹山变/10kV.10千伏I段母线	10	7160	4065.70
月开1号221线	10531	D5000维护值	4.92	2021-06-15	0.93	轻载	6352.630		扬州.谢集变/2号主变	20.16	扬州.谢集变/10kV.10千伏II段母线	1	630	6352.630
月开2号118线	10531	D5000维护值	5.37	2021-05-10	1.01	轻载	6344.840		扬州.谢集变/1号主变	19.38	扬州.谢集变/10kV.10千伏I段母线	0		6344.840
跃进131线	10455	D5000维护值	146.26	2021-05-19	32.15	轻载	2983.20		扬州.青矿变/3号主变	35.42	扬州.青矿变/10kV.10千伏III段母线	71	16895	2983.20
云馨148线	10455	D5000维护值	0	2021-04-01	0	轻载	5516.420		扬州.胥南变/3号主变	32	扬州.胥南变/10kV.10千伏IV段母线	0		5516.420
枣北122线	10530	D5000维护值	127.28	2021-06-07	24.02	轻载	4221.230		扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		4221.230
枣环1号115线	10530	D5000维护值	63.35	2021-06-12	11.95	轻载	5328.50		扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	20	16130	5328.50
枣环2号132线	10530	D5000维护值	108.97	2021-06-12	20.56	轻载	4538.360		扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	43	16930	4538.360
枣林134线	10530	D5000维护值	0.09	2021-04-30	0.02	轻载	6424.160		扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		6424.160
枣南119线	10530	D5000维护值	55.26	2021-06-15	10.43	轻载	5468.620		扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	0		5468.620
枣园136线	10530	D5000维护值	0.06	2021-06-26	0.01	轻载	6424.680		扬州.枣林变/2号主变	35.68	扬州.枣林变/10kV.10千伏III段母线	0		6424.680
枣云212线	10530	D5000维护值	0.07	2021-06-14	0.01	轻载	6424.510		扬州.枣林变/1号主变	33.27	扬州.枣林变/10kV.10千伏I段母线	0		6424.510
张集131线	10531	D5000维护值	136.68	2021-06-03	25.74	轻载	4070.550		扬州.方桥变/2号主变	32.08	扬州.方桥变/10kV.10千伏III段母线	0		4070.550
张集202线	10400	D5000维护值	0	2021-04-01	0	轻载	4849.60		扬州.新集变/1号主变	7.98	扬州.新集变/10kV.10千伏I段母线	18	5995	4849.60
张山117线	10459	D5000维护值	121.7	2021-06-23	26.51	轻载	3457.070		扬州.金马变/1号主变	23.74	扬州.金马变/10kV.10千伏I段母线	77	17765	3457.070
张云125线	10531	D5000维护值	359.04	2021-06-30	67.62	中载	219.270		扬州.郁桥变/1号主变	19.76	扬州.郁桥变/10kV.10千伏II段母线	3	6780	219.270
中电116线	10600	D5000维护值	476.97	2021-04-04	79.5	重载	0		扬州.三益变/1号主变	9.45	扬州.三益变/10kV.10千伏I段母线	1		0

中环123线	10	531	D5000维护值	182.99	2021-06-30	34.46	轻载	3268.46	0	扬州.矿区变/2号主变	4.36	扬州.矿区变/10kV.10千伏II段母线	0		3268.46
中江1号121线	10	469	D5000维护值	206.94	2021-06-10	44.12	轻载	2101.96	0	扬州.曹山变/2号主变	27.01	扬州.曹山变/10kV.10千伏II段母线	3	8730	2101.96
中桥163线	10	531	手工维护值	81.15	2021-05-18	15.28	轻载	5032.33	0	扬州.胥南变/1号主变	12.91	扬州.胥南变/10kV.10千伏VI段母线	20	13570	5032.33
中体143线	10	550	D5000维护值	90.17	2021-05-14	16.39	轻载	5106.46	0	扬州.仪城变/2号主变	40.44	扬州.仪城变/10kV.10千伏IV段母线	17	12180	5106.46
中兴212线	10	531	D5000维护值	160.77	2021-06-28	30.28	轻载	3653.31	0	扬州.圩区变/1号主变	34.64	扬州.圩区变/10kV.10千伏I段母线	0		3653.31
中源132线	10	531	D5000维护值	70.94	2021-05-11	13.36	轻载	5209.16	0	扬州.城南变/2号主变	27.68	扬州.城南变/10kV.10千伏III段母线	9	5680	5209.16
朱桥112线	10	531	手工维护值	255.24	2021-04-29	48.07	轻载	2017.09	0	扬州.大仪变/1号主变	32.57	扬州.大仪变/10kV.10千伏I段母线	119	36865	2017.09
砖瓦116线	10	531	D5000维护值	139.36	2021-06-29	26.24	轻载	4024.13	0	扬州.仪城变/1号主变	38.63	扬州.仪城变/10kV.10千伏I段母线	17	6220	4024.13
奥林511线	20	455	D5000维护值	57.68	2021-05-23	12.68	轻载	9034.8	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏I段母线	0		9034.8
冠天533线	20	455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏III段母线	0		11032.84
精卫531线	20	455	D5000维护值	2.46	2021-06-23	0.54	轻载	10947.63	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏III段母线	0		10947.63
精细513线	20	455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏I段母线	0		11032.84
君竹512线	20	455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏I段母线	0		11032.84
凯东524线	20	455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏II段母线	0		11032.84
凯西534线	20	455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏III段母线	0		11032.84
凯旋523线	20	455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏II段母线	0		11032.84
矿化515线	20	455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏I段母线	0		11032.84

矿南522线	20459	D5000维护值	58.38	2021-06-22	12.72	轻载	9107.55	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏II段母线	13	11855	9107.55
蓝田545线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏IV段母线	0		11032.84
美轮525线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏II段母线	0		11032.84
青霄521线	20459	D5000维护值	133.29	2021-06-24	29.04	轻载	6512.67	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏II段母线	13	8985	6512.67
天启514线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/1号主变	58.13	扬州.青矿变/20kV.20千伏I段母线	0		11032.84
万化532线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏III段母线	0		11032.84
小庄541线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏IV段母线	0		11032.84
肖青I号526线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	江苏.肖山变/1号主变	123.1	江苏.肖山变/20kV.20千伏II段母线	0		11032.84
肖青II号541线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	江苏.肖山变/2号主变	88.41	江苏.肖山变/20kV.20千伏IV段母线	0		11032.84
许工542线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏IV段母线	0		11032.84
赵会544线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏IV段母线	0		11032.84
周化535线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏III段母线	0		11032.84
周庄543线	20455	D5000维护值	0	2021-04-01	0	轻载	11032.84	0	扬州.青矿变/3号主变	35.42	扬州.青矿变/20kV.20千伏IV段母线	0		11032.84